



DRINKING WATER ANALYSIS REPORT

Elemental Solutions, LLC

P.O. Box 59203, Schaumburg, IL 60173

www.elementalsolutionsllc.com

Prepared For:	Coretta Scott King
Report Attention To:	Keith McLean
Sample Collection Date(s):	8/17/2019
Sample Collection Volume:	250mL
Date & Time of Last System Use:	8/17/19 5pm

Analysis Parameter:	Lead by EPA 200.8; MRL = 1ppb
Analysis Date(s):	8/22/2019
Laboratory:	PDC Labs

Sampling Location	Sample ID	Result (µg/L)	Comments
CSK Rm 105 Boys F1	9083811-01	<1.00	under the action limit
CSK Rm 105 Boys F1 2D	9083811-02	<1.00	under the action limit
CSK Rm 105 Boys F2	9083811-03	<1.00	under the action limit
CSK Rm 105 Boys F2 2D	9083811-04	<1.00	under the action limit
CSK Rm 105 Girls F2	9083811-05	1.44	under the action limit
CSK Rm 105 Girls F2 2D	9083811-06	<1.00	under the action limit
CSK Rm 123 Boys F1	9083811-07	2.99	above the action limit
CSK Rm 123 Boys F1 2D	9083811-08	<1.00	under the action limit
CSK Rm 123 Boys F2	9083811-09	6.80	above the action limit
CSK Rm 123 Boys F2 2D	9083811-10	<1.00	under the action limit
CSK Rm 124 Girls F1	9083811-11	3.98	above the action limit
CSK Rm 124 Girls F1 2D	9083811-12	1.14	under the action limit
CSK Rm 124 Girls F2	9083811-13	7.30	above the action limit
CSK Rm 124 Girls F2 2D	9083811-14	<1.00	under the action limit
CSK Rm 124 Girls F3	9083811-15	5.52	above the action limit
CSK Rm 124 Girls F3 2D	9083811-16	<1.00	under the action limit
CSK Rm 135 Boys F1	9083811-17	<1.00	under the action limit
CSK Rm 135 Boys F1 2D	9083811-18	<1.00	under the action limit
CSK Rm 135 Boys F2	9083811-19	<1.00	under the action limit
CSK Rm 135 Boys F2 2D	9083811-20	<1.00	under the action limit
CSK Rm 135 Grils F1	9083811-21	33.00	above the action limit
CSK Rm 135 Grils F1 2D	9083811-22	14.90	above the action limit
CSK Rm 135 Grils F2	9083811-23	<1.00	under the action limit
CSK Rm 135 Grils F2 2D	9083811-24	<1.00	under the action limit
CSK Rm 135 Grils F3	9083811-25	2.11	above the action limit
CSK Rm 135 Grils F3 2D	9083811-26	<1.00	under the action limit
CSK Gym Girls F1	9083811-27	1.14	under the action limit
CSK Gym Girls F1 2D	9083811-28	<1.00	under the action limit
CSK Gym Boys F1	9083811-29	5.98	above the action limit
CSK Gym Boys F1 2D	9083811-30	<1.00	under the action limit
CSK Gym Boys F2	9083811-31	6.50	above the action limit
CSK Gym Boys F2 2D	9083811-32	1.49	under the action limit